

RECOMMENDED SPARES LIST

CUSTOMER NAME	ALSTOM POWER CENTRALES - BELFORT	VENDOR CONTRACT N°	WH/00071	DATE	21-May-07
PROJECT NAME	MARITZA EAST 1 BULGARIA	DOCUMENT N°	RSL/CW32703/01 & 02	AFTERMARKET REF	DGE/070206/IRSL8
CUSTOMER PO N°	745117 P12 73077	REV STATUS	0	CONTACT	D.G. EDWARDS

Qty Of Valves	2 OFF	Description	SD Globe 6" ANSI 2500
---------------	-------	-------------	-----------------------

Tag N°	Serial N°	Qty Installed Per Valve	CD Drawing N°	Drawing Item	Description	Part N°	Notes	Recommended 2 Yrs Operation
--------	-----------	-------------------------	---------------	--------------	-------------	---------	-------	-----------------------------

01/02LAB40AA012	CW32703/01 & 02	1	CD32703	3,4,5,18,20,21,25,33,39	Assy Trim, Raven 6" 4T 38P Consisting Of #	C99106SAQA		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	3+	Plug #	C33774-XMC		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	4+	Trim Slack #	C33773-AQA		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	5+	Seat#	SRG30410403		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	18+	Spirol Pin #	U20-120		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	20++	Trim Gasket #	S269034	1	4
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	21+	Trim Spacer #	C33775-XMC		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	22++	Trim Gasket #	S266166	1	4
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	25++	U Cup Seal #	VAS040101	1	4
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	33+	Seal Retainer #	RET3040101		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	39++	Retaining Ring #	S342267	1	4
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	50	Split Ring #	C32512-XMA		
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	51	Retaining Ring #	C32514-ZHE		
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	71	Seat Adaptor Ring #	ADR3060402		
01/02LAB40AA012	CW32703/01 & 02	12	CD32703	89	Split Ring Capscrew #	C32517-ZHR	1	12
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	107+	Locking Bar #	C32570-AQA	1	1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	142++	U Cup Seal #	C33778-BPP	1	4
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	6+	Stem	STM320326502		1
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	16++	Gland Packing	C15586-BPP	1	4
01/02LAB40AA012	CW32703/01 & 02	1	CD32703	46++	Pressure Seal	C30981ABPP	1	4
01/02LAB40AA012	CW32703/01 & 02	1	CD32703		Actuator Repair Kit	AKX25-257		1
				See Manual				

NOTES

COMMENTS

Please note that items marked with a [1], must be changed during an inspection or maintenance overhaul it should be ensured that these items are available before commencing the inspection.
Do Not Re-Use